



CAUTION
USE COPPER CONDUCTORS ONLY!
UNIT TERMINALS ARE NOT DESIGNED TO ACCEPT OTHER TYPES OF CONDUCTORS.
FAILURE TO DO SO MAY CAUSE DAMAGE TO THE EQUIPMENT.

ATTENTION
N'UTILISER QUE DES CONDUCTEURS EN CUIVRE!
LES BORNES DE L'UNITÉ NE SONT PAS CONÇUES POUR RECEVOIR D'AUTRES TYPES DE CONDUCTEURS.

PRECAUCIÓN
¡UTILICE ÚNICAMENTE CONDUCTORES DE COBRE!
LAS TERMINALES DE LA UNIDAD NO ESTÁN DISEÑADAS PARA ACEPTAR OTROS TIPOS DE CONDUCTORES.

DEVICE DESIG	DESCRIPTION	LINE NUMBER
1F7	FUSE - COMPRESSOR PROTECT	125
1F8	FUSE - COMPRESSOR PROTECT	141
1U22	KEYPAD - CONDENSER FAN V.F.D. #1	156
1U23	KEYPAD - CONDENSER FAN V.F.D. #2	161
1U3	MODULE - MCM	121
2B101	MODULE - COMPRESSOR PROTECTION	125
2B202	MODULE - COMPRESSOR PROTECTION	125
2B303	MODULE - COMPRESSOR PROTECTION	141
2B404	MODULE - COMPRESSOR PROTECTION	141
2L2	SOLENOID - CHARGE ISOLATION CKT #2	143
2RT1	SENSOR - SATURATED COND TEMP	128
2RT2	SENSOR - SATURATED COND TEMP	144
2S10	SWITCH - LOW PRESSURE CUTOFF	148
2S12	SWITCH - HIGH PRESSURE CUTOFF	125
2S13	SWITCH - HIGH PRESSURE CUTOFF	141
2S9	SWITCH - LOW PRESSURE CUTOFF	132
2U20	V.F.D. - CONDENSER FAN #1	158
2U21	V.F.D. - CONDENSER FAN #2	163
5L4	SOLENOID - CHARGE ISOLATION CKT #1	126
5L5	SOLENOID - CHARGE ISOLATION CKT #2	144
6RT10	SENSOR - LEAVING EVAP TEMP	142
6RT6	SENSOR - ENTERING EVAP TEMP	124
6RT7	SENSOR - ENTERING EVAP TEMP	140
6RT9	SENSOR - LEAVING EVAP TEMP	126

REF DES	DESCRIPTION	LINE NO.
1K1	CONTACTOR - COMPRESSOR	146
1K2	CONTACTOR - COMPRESSOR	148
1K3	CONTACTOR - COMPRESSOR	130
1K4	CONTACTOR - COMPRESSOR	128
1K9	CONTACTOR - CONDENSER FAN	134
1K10	CONTACTOR - CONDENSER FAN	132
1K11	CONTACTOR - CONDENSER FAN	152
1K12	CONTACTOR - CONDENSER FAN	150

THIS DRAWING IS THE PROPERTY OF AMERICAN STANDARD INC. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED ON THIS DRAWING. PARTS LISTED HEREIN ARE THE PROPERTY OF AMERICAN STANDARD INC. AND ARE NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

DATE: 12-14-06
REVISION DATE: 5-25-07
DRAWN BY: K. RYAN
CHECKED BY: J. JAGRAM
PROJ: JAGRAM

FILE NUMBER: 2309-3635
DRAWING NUMBER: ROOF-TOP PACKAGED AIR CONDITIONER DIAGRAM
SHEET: 1 OF 1
REV: E

CONTROLS - MULTI-CIRCUIT COMPRESSOR MODULE (MCM) - 2/3-PC
90-150T WITHOUT LOW AMBIENT OPTION
130T-150T WITH LOW AMBIENT OPTION
SHEET 3 OF 7