



NOTE(S):

1. UNLESS OTHERWISE NOTED, ALL SWITCHES ARE SHOWN AT 25° C (77° F), AT ATMOSPHERIC PRESSURE, AT 50% RELATIVE HUMIDITY, WITH ALL UTILITIES TURNED OFF, AND AFTER A NORMAL SHUTDOWN HAS OCCURRED.
2. DASHED LINES INDICATE RECOMMENDED FIELD WIRING BY CONTRACTOR. DASHED LINES AND ENCLLOSURES OR DASHED DEVICE OUTLINES INDICATE COMPONENTS PROVIDED BY THE FIELD. PHANTOM LINED ENCLLOSURES INDICATE ALTERNATE CIRCUTRY OR AVAILABLE SIZES OPTIONS. SOLID LINES INDICATE WIRING BY TRANE.
3. ALL FIELD WIRING MUST BE IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE (NEC), STATE AND LOCAL CODES AND STANDARDS. ALL FIELD WIRING MUST HAVE AN INSULATION VOLTAGE RATING THAT EQUALS OR EXCEEDS UNIT RATED VOLTAGE.
4. WIRING SHOWN IS FOR MODULATING DAMPER SECTION, FOR FIELD INSTALLED MODULATING DAMPER AND 2 POSITION DAMPER.
5. WIRING SHOWN IS FOR WALL MOUNTED DISPLAY ZONE SENSOR. FOR OTHER OPTIONS ZONE SENSOR, SEE INSET "G".
6. USE CLASS 2 WIRING.
7. REMOVE TEST JUMPER PRIOR TO CONNECTING MIXING BOX TO UNIT.

DEVICE PREFIX LOCATION CODE	
AREA	LOCATION
1	MAIN CONTROL PANEL
2	SUPPLY FAN AND COIL SECTION
3	
4	MIXING BOX SECTION
5	EXTERNAL PIPING
6	ELECTRIC HEAT CONTROL BOX
7	FIELD INSTALLED DEVICE

[illegible]

TRANE THE TRANE COMPANY 10000 W. 15TH AVE. MINNEAPOLIS, MN 55426 TEL: 612-576-6000 FAX: 612-576-6001 WWW.TRANE.COM	50262938
--	----------