



DEVICE PREFIX LOCATION CODE	
AREA	LOCATION
1	CONTROL PANEL
2	CONTROL END
3	PIPING END
4	FAN SECTION
5	COIL SECTION
6	CUSTOMER INSTALLED
7	FIELD SUPPLIED DEVICE

LEGEND		
DEVICE DESIGNATION	DESCRIPTION	LINE NUMBER
1U1	UC400-B, SYMBIO 400-B MODULE	74
1U3	ECM ENGINE BOARD	115
1S4	DX FROSTSTAT	84
2U3	AIR-FI WIRELESS COM INTERFACE	85
1R1	RESISTOR; DX STG 1 TEST	89,123
1R2	RESISTOR; HEATPUMP TEST	122
5RT5	DISCHARGE AIR TEMP SNSR	91
7U1	CO2 SENSOR	93
3L2	HEATING COIL VALVE	94,126,128
7L2	HEATING COIL VALVE	94,126,128
3S8	CONDENSATE OVERFLOW SWITCH	96
3RT1	AUTOCHG TEMP SENSOR\ EH LO	100
6U8	ZONE HUMIDITY SENSOR	122

REPLACES		TRANE	3518-6106	REV
REVISION DATE	DESIGNED BY			
24-JUL-2023	G.HUDONS	NO CHANGE TO EXISTING WIRING. THIS SCHEMATIC IS FOR INFORMATION ONLY. IT DOES NOT REPLACE THE EXISTING WIRING. © TRANE	UC400-B, SYMBIO 400-B DX COIL W/ OR W/O HEAT PUMP FAN COIL/FORCE-FLO	